

FIG. 1
Prior Art




FIG. 2
Prior Art




FIG.3
Prior Art




FIG. 4




FIG. 5




FIG. 6

S130




FIG. 7

S140




FIG. 8




FIG. 9




FIG.10

S170




FIG. 11




FIG. 12




FIG.13




FIG. 14




FIG.15

S243





FIG.16



0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99

FIG.18




FIG.19A

◆heat transfer loss—inside surface,floor(except outside wall and roof) ⑤					
item	direction coetticient	area	temperature difference	K	heating load
cieling	(A)	cb	⑤	cj	(D)
floor	(A)	cc	⑤	ck	(D)
partition	(A)	cd	⑤	cl	(D)

◆room heat loss—ventilation				
item	air volume	temperature difference	coefficient	heating load
ventilation	(A)	⑤	0.288	(F)

◆room heat loss—ventilation				
item	coefficient	absolute humidity difference	air volume	amount of added
amount	1.2	⑨	(E)	(F)
load	moist amount*600		(H)	

◆heating load	sum	Total
---------------	-----	-------

09003687.062901

FIG.19A

◆heat transfer loss-glass					
item	direction coefficient	area	temperature difference	K	heating load
glass	(A)	y	⑤	ci	(B)
	(A)	y	⑤	ci	(B)
	(A)	y	⑤	ci	(B)
	(A)	y	⑤	ci	(B)

◆heat transfer loss-outside wall					
item	direction coefficient	area	temperature difference	K	heating load
outside wall	(A)	bf	⑤	bp	(C)
	(A)	bg	⑤	bq	(C)
	(A)	bh	⑤	br	(C)
	(A)	bi	⑤	bs	(C)
roof	(A)	bj	⑤	bt	(C)

(A) : direction coefficient

(B) : direction coefficient*area* temperature difference *K

(C) : direction coefficient*area* temperature difference *K

(D) : direction coefficient*area* temperature difference *K

(E) : number ventilation air change

(F) : air volume*temperature difference*coefficient

(G) : coefficient *absolute humidity difference*air volume

(H) : amount of added moist*600

Total : (B)+(C)+(D)+(F)+(H)

☐ heat generation from other apparatuses(kcal/hr)

apparatus	sensible heat	latent heat	remark
lighting, electric heater(per kw)	860	—	
fluorescent lamp(per kw)	1,000	—	
coffee pot 1.0Lit(GAS)	100	25	
toaster 15 x 28 x 23cm(electric heat)	610	110	
domestic stove	1,800	200	
hair dryer for beauty parlor(115v)	470	80	
motor(94~375w)	1,060	—	
motor(0.375~2.25kw)	920	—	
motor(2.25~15kw)	740	—	
refrigerator,fan(0~0.4kw)	1,140	—	
refrigerator,fan(0.75~3.7kw)	1,100	—	
refrigerator,fan(3.7~15kw)	1,000	—	

$$\text{load of incandescent lamp(kcal/h)} = \text{watt} \times 0.86$$
$$\begin{aligned}\text{load of fluorescent lamp(kcal/h)} &= \text{watt} \times 1.25 \times 0.86 \\ &= \text{watt} \times 1.08\end{aligned}$$

the 1.25 times in the load of fluorescent lamp is for a power consumption of ballast

FIG.19C

working state	working state		28(°C)		27(°C)		26(°C)		24(°C)	
	site	total heat generation	(SH)	(LH)	(SH)	(LH)	(SH)	(LH)	(SH)	(LH)
sit on chair	theater	88	44	44	49	39	53	35	58	65
light work	school	101	45	56	49	52	53	48	61	69
office work	office, hotel, department store	113	45	68	50	63	54	59	62	72
sit/stand	bank	126	45	81	50	76	55	71	64	73
sit and work	dining room/ quest room	139	48	91	56	83	62	77	71	81
sit and work	light workate factory	189	48	141	56	133	62	127	74	92
general dancing	dance hall	215	56	159	62	153	69	146	82	101
walk(4.8km/h)	factory	252	68	184	76	176	83	189	96	116
bowling	bowling lane	365	113	252	117	248	121	244	132	153